JOB NO.	DWG NO.
1194	E-03-801

REFERENCE DRAWINGS	DWG NO.



> Transparent window for instant visibility of protection devices

> Double mechanical interlocking switch cannot be turned on unless a plug is inserted. Plug cannot be removed when the switch is on

DISTRIBUTION ASSEMBLY DETAIL

(FOR EXACT NO. OF OUTLET AND TYPE REFER TO LEGEND)



FUME CUPBOARD POWER BOX SCHEMATIC DIAGRAM. ( ) (TYP.)
SHALL BE LOCATED OUTSIDE FUME CUPBOARD



WORKBENCH POWER BOX SCHEMATIC DIAGRAM. ( ) (TYP.)



INSTALLATION OF UNDER SCREED TRUNKING

IN TRAINING ROOMS/LABS (TYPICAL)



ELEVATION
DIMENSIONS SHOWN ARE INDICATIVE ONLY

SECTIONAL VIEW

ROUTING AND GLANDING OF ARMOURED CABLES

IN RECESS MOUNTED FINAL DISTRIBUTION BOARD





CABLE AND CORE MARKING



CABLE TRAY ON FLOOR

PROVIDED WITH VENTILATED COVER



TYPICAL CABLE TRUNKING ARRANGEMENT/MOUNTING DETAIL



CABLE TRAY SUSPENDED FROM CEILING



INSTALLATION DETAIL
FOR DBs - FED BY CABLES
N.T.S



CEILING MOUNTED CABLE TRAY



CABLE TRAY BONDING



WALL MOUNTED CABLE TRAY

NOTE-

1. EXACT METHOD OF JOINTING THE CABLE TRAYS SHALL BE IN ACCORDANCE WITH THE RESPECTIVE MANUFACTURERS RECOMMENDATIONS AND SHALL INCORPORATE ALL NECESSARY PROPRIETARY COMPONENTS.
2. THE PRECISE DIMENSION AND SIZE OF ASSOCIATED EXPANSION ANCHOR BOLTS SHALL BE IN ACCORDANCE WITH BOTH THE RESPECTIVE MANUFACTURERS RECOMMENDATIONS AND TO SUIT THE PROPRIETARY COMPONENT.

CLIENT :

أدنوك
ADNOC
شركة بترول أبوظبي الوطنية

G.F	M.F	K.S	M.N	M.N	ISSUED FOR TENDER	13/11/08	0
PROJ APPROVED	TEAM	JOB ENG	CHK	BY	REVISIONS	DATE	REV NO.

PROJECT :

BOROUGE INNOVATION CENTER
IN ABU DHABI
AGREEMENT NO:II5984DI - PROJECT NO.5984

END USER :

بروج
Borouge

CONSULTANT :

ECG
ENGINEERING CONSULTANTS GROUP S.A. ABU DHABI

P.O. BOX 29556,
ABU DHABI, U.A.E
TEL : +02-6728-007
FAX : +02-6726-02
e-mail : ecg emirates.net.ae

LABORATORY BUILDING

GENERAL DETAILS

(SHEET 1/2)

SCALE	JOB NO.	DWG NO.	REV NO.
NTS	1194	E-03-801	0

FILENAME

AI